

Water Plant			Distribution					Water Usage		Comments
Month	Turbidity (NTU)	Chlorine (SU)	PH	Chlorine (mg/L)	Bacteriological (#/100ml)	TTHM	HAAS	Water Produced	Monthly Avg	
Jan	N/A	N/A	N/A	N/A	N/A	N/A	N/A	2,561,884	82,641	
Feb	0.037	1.62	7.93	0.53	0	26.3	9.7	2,444,313	87,297	
Mar	0.04	1.73	7.92	0.93	0			2,153,446	69,466	
1st Quarter Avg	0.039	1.68	7.93	0.78	0	26.3	9.7	7,159,643	79,801	TTHM MCL = 80 mg/L HAAS MCL = 60 mg/L Turbidity MCL = 0.10 NTU Chlorine Hi= 4.0 mg/L Chlorine Lo = 0.20 mg/l
Apr	0.038	1.8	7.92	0.5	0			2,611,865	87,062	
May	0.04	1.67	7.71	0.85	0	69.4	41.7	2,714,730	87,572	
Jun	0.041	2.02	7.36	0.53	0			3,208,822	106,961	
2nd Quarter Avg	0.04	1.83	7.66	0.62	0	69.4	41.7	8,535,417	93,865	TTHM MCL = 80 mg/L HAAS MCL = 60 mg/L Turbidity MCL = 0.10 NTU Chlorine Hi= 4.0 mg/L Chlorine Lo = 0.20 mg/l
Jul										
Aug										
Sep										
3rd Quarter Avg										TTHM MCL = 80 mg/L HAAS MCL = 60 mg/L Turbidity MCL = 0.10 NTU Chlorine Hi= 4.0 mg/L Chlorine Lo = 0.20 mg/l
Oct										
Nov										
Dec										
4th Quarter Avg										TTHM MCL = 80 mg/L HAAS MCL = 60 mg/L Turbidity MCL = 0.10 NTU Chlorine Hi= 4.0 mg/L Chlorine Lo = 0.20 mg/l